

1005.330 Underground Wiring For Subdivisions.

All electric and telephone distribution lines shall be installed underground, except those overhead distribution feeder lines necessary to serve that subdivision and in locations as approved by the Department. Cable switching enclosures, pad mounted transformers, and service pedestals may also be installed above ground and may be installed as a part of the street lighting standards where approved by the Department. The Department may approve above ground installations in whole or part for non-residential subdivisions only when a request is submitted by the developer with documentation that supports the impracticability of installing such utility lines underground. (O. No. 12035 - Adopted 4/25/85)

1005.330-1